



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

CERTIFICATE OF ANALYSIS

Product: HFC-134A

Batch No.: 1708076

Standard: GB/T18826-2016

Report date: 15012023

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	%(\geq)	99.9	99.9
Moisture	%(\leq)	0.001	0.0009
Acidity	(as HCL)% \leq	0.0001	\leq 0.0001
Non condensable gas	(V/V) % \leq	1.5s	1.1
Conclusion	QUALIFIED		
Remark	WBA044/YH1701		

浙江永和制冷股份有限公司
ZHEJIANG YONGHE REFRIGERANT CO.,LTD.

李建国