



ZHEJIANG YONGHE REFRIGERANT CO., LTD.
CERTIFICATE OF ANALYSIS

Product: R404A

Batch No.: 2-2303211H

Standard: Q/ZYH005-2022

Report date: 230322

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	%(\geq)	99.9	99.95
R125/R143a/R134a (%)		42~46/51~53/2~6	44.0/52.0/4.0
Moisture	%(\leq)	0.001	0.0008
Acidity	(as HCL)% \leq	0.0001	\leq 0.0001
Non condensable gas	(V/V) % \leq	1.5	1.0
Conclusion	QUALIFIED		
Remark	TANK NO.:ZHLU2010146 WBA044/YH2307-6		

Inspector: Xu jianfu Review: Liu wangxing Check: Liu wangxing