



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

CERTIFICATE OF ANALYSIS

Product: R410A

Batch No.: 1709012

Standard: Q/ZYH013-2016

Report date: 15012023

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	%( $\geq$ )	99.9	99.96
Moisture	%( $\leq$ )	0.001	0.0009
Acidity	(as HCL)% $\leq$	0.0001	$\leq$ 0.0001
Non condensable gas	(V/V) % $\leq$	1.5	0.7
Conclusion	QUALIFIED		
Remark	WBA044/YH1701		

浙江永和制冷股份有限公司  
ZHEJIANG YONGHE REFRIGERANT CO., LTD.

李建国