



ZHEJIANG YONGHE REFRIGERANT CO., LTD.
CERTIFICATE OF ANALYSIS

Product: R417A

Batch No.: 1810093

Standard: Q/ZYH011-2016

Report date: 180123

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	%(\geq)	99.9	99.92
Moisture	%(\leq)	0.001	0.0009
Acidity	(as HCL)% \leq	0.0001	\leq 0.0001
Non condensable gas	(V/V) % \leq	1.5	0.7
Conclusion	QUALIFIED		
Remark	WBA044/YH1837 浙江永和制冷股份有限公司 ZHEJIANG YONGHE REFRIGERANT CO.,LTD.		

李建国