



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

CERTIFICATE OF ANALYSIS

Product: R507

Batch No.: 1-2103282

Standard: Q/ZYH012-2019

Report date: 19012023

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	%(\geq)	99.9	99.94
R125/R143a		49.5~51.5/48.5~50.5	50.2/49.8
Moisture	%(\leq)	0.001	0.0009
Acidity	(as HCL)% \leq	0.0001	\leq 0.0001
Non condensable gas	(V/V) % \leq	1.5	1.1
Conclusion	QUALIFIED		
Remark	WBA044/YH2112-1		

浙江永和制冷股份有限公司
ZHEJIANG YONGHE REFRIGERANT CO., LTD.