



ZHEJIANG YONGHE REFRIGERANT CO., LTD.

CERTIFICATE OF ANALYSIS

Product: R32

Batch No. : 1809101

Standard: HG/T4634-2014

Report date: 180123

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	%( $\geq$ )	99.80	99.96
Moisture	%( $\leq$ )	0.0010	0.0009
None Condensable Air	(25°C)%	1.5	0.8
Acidity	(as HCL)% $\leq$	0.00001	$\leq$ 0.00001
Vapor Residue	%( $\leq$ )	0.01	$\leq$ 0.01
Conclusion	QUALIFIED		
Remark	WBA044/YH1828		

浙江永和制冷股份有限公司  
ZHEJIANG YONGHE REFRIGERANT CO.,LTD.

李建国